



GREATER VISAKHAPATNAM MUNICIPAL CORPORATION
FIRE PREVENTION WING

From,
The Commissioner,
Greater Visakhapatnam
Municipal Corporation
Visakhapatnam.

To,
The District Educational Officer,
Visakhapatnam District,
Visakhapatnam.

Rc.No.408/RFO/FPW/GVMC/2024, Dt.10/10/2024

SUB: Greater Visakhapatnam Municipal Corporation – Fire Prevention Wing - Existing Building of M/s.AD School (E.M), Phoolbagh Road Gavarapalem, Anakapalli, Visakhapatnam – **Renewal of Fire No Objection Certificate** - Issued - Reg.

REF: 1. Letter Rc.No:5041/B2/97 of Director General, A.P Disaster Response & Fire Services Department, Dated: 12-03-2010.
2. Delegation orders of the Commissioner, GVMC vide Rc.No.6721/2012/TP. Sec/G1, Dt: 13-09-2019.
3. This office Fire No Objection Certificate for Occupancy issued vide Rc.No.00391/RFO/FPW/GVMC/2020, Dt.12-11-2020.
4. This office Renewal of Fire NOC issued vide Rc.No.247/RFO/FPW/GVMC/2024, Dt.02-07-2024.
5. Application Dt.27-06-2024 of M/s.AD School (E.M), Phoolbagh Road Gavarapalem, Anakapalli, Visakhapatnam for Renewal of Fire No Objection Certificate.

It is to inform that, vide reference 3rd cited, Fire No Objection Certificate for Occupancy was issued to M/s.AD School (E.M), Phoolbagh Road Gavarapalem, Anakapalli, Visakhapatnam and vide reference 4th cited, the management obtained Renewal of Fire NOC.

2) Vide reference 5th cited, an application is received for issuance of Renewal of Fire No Objection Certificate to the same building.

3) Therefore, the Inspection Committee of Fire Prevention Wing inspected the premises of M/s.AD School (E.M), Phoolbagh Road Gavarapalem, Anakapalli, Visakhapatnam on 10-10-2024 and submitted the following report.

4) Particulars of the building:

a)	Address of the Premises	M/s.AD School (E.M), Phoolbagh Road Gavarapalem, Anakapalli, Visakhapatnam
b)	Total Plot Area	1021.25 Sq.Mtrs.
c)	Height of the Building	14.95 Mtrs.
d)	No of blocks/ floors	01 Block / Stilt + Ground + 03 Upper Floors
e)	Type of occupancy	Educational (School)

5) The floor wise details

Sl. No.	Floor	Area in Sq. Meters.	Type of Occupancy
1.	Stilt	769.00	Parking



2.	Ground	769.00	Educational (School)
3.	First	769.00	Educational (School)
4.	Second	769.00	Educational (School)
5.	Third	769.00	Educational (School)
	Total	3845.00	

6) The Management has provided the following open Spaces all around building:

Direction	Open space provided (In Mtrs.)
North	04.00
South	01.50
East (Front)	03.00
West	00.50

7) Means of Escape:

- The Management has provided One Internal Staircase with width of 1.10 Mtrs. from Stilt to Terrace and One External Staircase with width of 1.20 Mtr. from Ground to Third floor.

8) The Minimum Fire Safety Installations required & provided by the Builder.

Sl. No.	Fire Fighting Systems	Required	Provided	Deficit
1.	Fire Extinguishers as per IS 2190	40 Nos.	40 Nos.	Nil
2.	Hose Reel	05 Nos.	05 Nos.	Nil
3.	Down Comer	01 No.	01 No.	Nil
4.	Terrace Tank	10,000 Ltrs.	10,000 Ltrs.	Nil
5.	Booster Pump	450 LPM	450 LPM	Nil
6.	Water Shower curtains	03 sides	03 sides	Nil

9. The management has remitted an amount of Rs.57,675/- vide challan No.202-CA-11553, Dt.08-10-2024 towards fire precautionary fees for 03 years renewal period.

10. The Fire safety systems were tested by the Inspection Committee, Fire Prevention Wing, GVMC during the inspection and performance found satisfactory and recommended for issuance of Renewal of Fire No Objection Certificate.

11. Therefore, **Renewal of Fire No Objection Certificate** is hereby issued to the Educational Building of M/s.AD School (E.M), Phoolbagh Road Gavarapalem, Anakapalli, Visakhapatnam subject to the following conditions:

i.	All the protection arrangements shall be maintained in good condition as seen during inspection
ii.	All the escape / exit routes shall not be kept locked / blocked or encroached
iii.	All the occupants must know the correct method of operation of the fire fighting system installed
iv.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v.	All students / staff members of the institution shall be trained to operate the fire safety



	equipments during Emergency.
vi.	Addition / alteration, if any in the building may be obtained with prior permission from this department.
vii.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

12.The **Renewal of Fire No Objection Certificate** issued to M/s.AD School (E.M), Phoolbagh Road Gavarapalem, Anakapalli, Visakhapatnam is **valid for three (03) years from 12-11-2024 to 11-11-2027** and the Management shall submit the application for Renewal of Fire No Objection Certificate two (2) months before the date of expiry.

13.The issuing of Fire NOC without any prejudice to action taken by GVMC against Unauthorized Construction, if any made.

Y HANUMANTHA RAO, RFO(YHR)-RFO(TP)-GVMC, O/o REGIONAL FIRE OFFICER-TOWN PLANNING-GVMC

Regional Fire Officer

Copy to the management, M/s AD School (E.M), Phoolbagh Road Gavarapalem, Anakapalli, Visakhapatnam.

